NON "UL" APPROVED PAINT BOOTH ADDENDUM

☐ Acceptance Indemnity Insurance Company
☐ Acceptance Casualty Insurance Company
☐ Occidental Fire & Casualty Insurance Company
☐ Wilshire Insurance Company

Applicant/Named Insured: _____

(DBA): _____

In the absence of a "UL" approved paint booth, all of the following must be complied with:

1. The paint booth is completely sealed from the rest of the shop area.
2. Exterior switches are present for all electrical items.
3. Explosion proof lighting has been installed.
4. Exhaust fan has been installed
5. The booth is built of material such as concrete, block and brick, etc. No frame construction unless covered by at least 5/8" fire rated sheetrock.
6. Adequate fire extinguishers are present.
7. Paint and other flammable materials are stored in a fire proof cabinet.

PLEASE REVIEW AND ACKNOWLEDGE THAT THE INSURED HAS COMPLIED WITH THE ABOVE REQUIREMENTS BY SIGNING BELOW.

_____	_____	_____
Applicant Name	Applicant Signature	Date
_____	_____	_____
Producer Name	Producer Signature	Date